


Figure 3.3 Current Density j at 1ns.



Graph 4.1 conductivity of Arc vs. time

2) Transient behavior:

The electric field and magnetic field values from the t=0 to t=1ns has been observed by model .The heat losses is rapidly increases during the t = 0+.As current zero achieved the direction of the j and E reversed as sinusoidal voltage and current has been applied and so at current zero heat looses is low and that is the time to open the contact so as much as safe operation has been followed and finally arc will extinguished.

4 ANALYSES OF THE SIMULATION

To find the characteristically behavior of the intercontact gap.

Using E and j values,

$j = \sigma E$ (8)

$\sigma = j/E$ (9)


$R = 1/\sigma$ (10)

Where,

- j=Current density in the air, (A/m²);
- E=Electric field intensity in air, (V/m)
- R=resistance of an arc, (Ω)
- σ = Conductivity of an Arc, (\bar{U})

Using above Equation (8) and (9),

The behavior of the arc is shown in graphs,



Graph 4.2 Resistivity of Arc vs. Time

5 CONCLUSION

The arc resistivity clearly shows that in the beginning at t=0 arc resistance in $10^6\Omega$ than rapidly decreased in the few ns. It is zero at 1.76×10^{-10} sec. Arc is taken place with thermal break down of the air. The current density rapidly starts increases as shown in the model, as this model shows the dynamic behavior of an arc.

5 ACKNOWLEDGMENTS

We would like to thanks Dr.M.K.Shah for his Support throughout the work. We would also like to thanks Dr.V.Shrinet for giving me lots of space to work in the technical environments.

6 REFERENCES

- [1] Wu Xi-xiu¹, Li Zhen-Biao², Tian Yun², Mao Wenjun³, Xie Xun, " Investigate on the Simulation of black box arc model," 2011 1st International Conference on Electric Power Equipment - Switching Technology - Xi'an - China, pp. 629-639,2011.
- [2] A. Iturregi¹, E. Torres², I. Zamora³ , " Analysis of the Electric Arc in Low Voltage Circuit Breakers," International Conference on Renewable Energies and Power Quality, Las Palmas de Gran Canaria (Spain), 13th to 15th April, 2011
- [3] William Bussire Pascal An Dr.David Rochette, Stphane Clain and Charles Besnard," Porous _lter optimization to improve the safetyof the medium-voltage electrical installations during an internal arc fault," IEEE transactions on power delivery, 25, no. 4, october2010.

7. BIOGRAPHIES



[1] **Mr. Jignesh Desai** was born in Surat, India. He received his bachelor of engineering in electrical from Veer Narmad South Gujarat University, surat.his currently interests in power system and electronics. He is perusing his M.tech Electrical from Nirma University.



[2]**Mrunal G Parekh** is a native of Bharuch, India. He received B.E. degree from the University of veer narmad south Gujarat and M.Tech degree from VJTI (Veermata Jijabai technological Institute), Mumbai both in electrical engineering.



[3]**A. P. Desai** has received the B.E degree in Electrical Engineering from South Veer Narmad South Gujarat University, Surat Gujarat, in 2008. Currently he studies in M.E. (electrical engineering) of Shantilal shah Engineering College, Bhavnagar Gujarat, India.